


FIGURE 8-BB

Reproduced by permission from the 1941 Guide of the American Society of Heating & Ventilating Engineers



	R/D					
	0.5	0.75	1.00	1.50	2.00	2.50
Stamped	0.71	0.33	0.22	0.15	0.13	0.12
5-piece	-	0.46	0.33	0.24	0.19	0.17*
4-piece	-	0.50	0.37	0.27	0.24	0.23*
3-piece	0.90	0.54	0.42	0.34	0.33	0.33*

\* extrapolated from published data


OTHER ELBOW LOSS COEFFICIENTS

- Mitered, no vanes 1.2
- Mitered, turning vanes 0.6
- Flatback (R/D = 2.5) 0.05 (see Figure 5-23)

NOTE: Loss factors are assumed to be for elbows of "zero length." Friction losses should be included to the intersection of centerlines.

ROUND ELBOW LOSS COEFFICIENTS

(Ref. 5.13)



R/D	Aspect Ratio, W/D					
	0.25	0.5	1.0	2.0	3.0	4.0
0.0(Mitre)	1.50	1.32	1.15	1.04	0.92	0.86
0.5	1.36	1.21	1.05	0.95	0.84	0.79
1.0	0.45	0.28	0.21	0.21	0.20	0.19
1.5	0.28	0.18	0.13	0.13	0.12	0.12
2.0	0.24	0.15	0.11	0.11	0.10	0.10
3.0	0.24	0.15	0.11	0.11	0.10	0.10

SQUARE & RECTANGULAR ELBOW LOSS COEFFICIENTS

AMERICAN CONFERENCE  
OF GOVERNMENTAL  
INDUSTRIAL HYGIENISTS

DUCT DESIGN DATA  
ELBOW LOSSES

DATE 1-95

FIGURE 5-13